

12. CITY MANAGER

a. Informational Items

xi. Public Works Grease Trap Inspection Report March, 2011

Grease Trap Monthly Activity Report



City of Sanibel
Public Works - Utility Division
800 Dunlop Road
Sanibel, FL 33957

March-11

NOV=Notice of Violation
AL=Advisory Letter

* click on the links to see attached documentation. (Inspection Forms, Letters and Notice of Violations)

Date	Business	Site Address	Inspection Dates	Inspection Report	Notice	Status
3/2/2011	Noopies Japanese Seafood and Steakhouse.(Sundial Beach Resort)	1451 Middle Gulf Drive Sanibel, FL 33957	3/2/2011 3/15/11	interceptors needs to be pumped interceptor was pumped	Sent AL 3/2/11	Complete
3/2/2011	Dairy Queen of Sanibel	1048 Periwinkle Way Sanibel, FL 33957	3/2/2011 3/15/11	interceptor needs to be pumped interceptor was pumped	Sent AL 3/2/11	Complete
3/18/2011	The Sanibel Bean	2240 Periwinkle Way Sanibel, FL 33957	3/18/2011 4/5/2011	interceptor needs to be pumped interceptor was pumped	Sent AL 3/21/11	Complete
3/18/2011	The Greenhouse Grill	2407 Periwinkle Way Sanibel, FL 33957	3/18/2011 4/5/2011	interceptor needs to be pumped interceptor was pumped	Sent AL 3/21/11	Complete
3/18/2011	George and Wendy's Corner Grill	2499 Periwinkle Way Sanibel, FL 33957	3/18/2011 4/5/2011 4/19/11	interceptor needs to be pumped interceptor was not pumped interceptor was pumped	Sent AL 3/21/11 Sent NOV 4/5/11	Complete
3/18/2011	IL Tesoro Ristorante	751 Tarpon Bay Road Sanibel, FL 33957	3/18/2011 4/5/2011 4/19/2011	interceptor needs to be pumped and install T & baffle on inlet side interceptor was not pumped & T was not installed interceptor was pumped and T & Baffle were installed	Sent AL 3/21/11 Sent NOV 4/5/11	Complete
3/18/2011	Jerry's Enterprises Inc.	1700 Periwinkle Way Sanibel, FL 33957	3/18/2011 4/5/2011 4/19/2011	Need to have interceptor #3 pumped and remove caps on T's in all interceptors interceptor was not pumped and caps were not removed interceptor was pumped and caps were not removed	Sent AL 3/21/11 Sent NOV 4/5/11	Forwarded to Code Enforcement
3/18/2011	Chips Sanibel Steakhouse	1473 Periwinkle Way Sanibel, FL 33957	3/18/2011 4/5/2011	interceptor needs to be pumped interceptor was not pumped	Sent AL 3/21/2011 Sent NOV 4/5/11	Have till April 22 to comply