

## **TEMPORARY TENT PERMIT STANDARDS**

1. A temporary tent permit is required for tents exceeding 120 square feet.
2. Tent fabric must be flame resistant and labeled accordingly.
3. Tents must have temporary lighting if occupied following sunset. Applicant must obtain an electrical permit and comply with the National Electrical Code for temporary electric or any other electric work related to the special event.
4. Tents shall have a 2A-10BC rated fire extinguisher within a distance of 75 feet of any enclosed space inside of the tent.
5. Egress aisles must be maintained within the tent at all times.
6. Tents may not be occupied during a thunderstorm.
7. Emergency vehicle access must be maintained along the perimeter of the tent at all times. Tent placement shall not obstruct emergency vehicle access to the property.
8. NO SMOKING signs must be posted in the tent.
9. Emergency lighting compliant with NFPA standards are required in tents exceeding 1200 square feet.
10. Upon erection of the tent and set-up of tables, chairs, aisles, entertainment area and catering area, please contact the Sanibel Fire District at (239) 472-5525 to schedule a fire inspection prior to event.
11. Within 24 hours following the event, the tent(s), furnishings and refuse shall be removed and the site shall be restored to its original condition. Upon completion, please call (239) 472-8321, for an inspection. Failure to schedule an inspection within 24 hours following the event will result in the forfeiture of deposit.