

7. CONSENT AGENDA

- d. Approval of an expenditure for an emergency repair at Lift Station #6 located on Sand Castle Road near Bailey Road with an estimate cost of \$85,757 (sufficient funds available in the FY10 adopted budget in the Sewer line item Fund 450)

MEMORANDUM

DATE: August 3, 2010

TO: City Council

THROUGH: City Manager Judie Zimomra

FROM: Public Works Director Gates Castle JOC

RE: Emergency Sewer Repair – Lift Station 6

RECOMMENDATION: Approval of expenditure for emergency repair at Lift Station 6

Lift Station 6, located in the Dunes on Sand Castle Road near Bailey Road, pumps / repumps all of the Dunes wastewater flow. The 15-foot deep sewer main between the collection manhole and the lift station wetwell collapsed, making the lift station inoperable. While the City bypass pumped the station, MAJ Contracting was hired to replace the collapsed main, at an estimate cost of \$85,757, although the final cost is not yet available.

In accordance with the City's Purchasing Policy #06-04, Council's after-the-fact approval of this expenditure is requested / recommended.

Cc: City Attorney Ken Cuyler
Finance Director Sylvia Edwards